

OPERATING DATA REPORT

DOCKET NO. 50 - 352

DATE JANUARY 14, 1992

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

KARL MECK

REPORTS SUPERVISOR

BUSINESS UNIT

LIMERICK GENERATING STATION

TELEPHONE (215) 327-1200 EXTENSION 3320

3931019070

OPERATING STATUS

1. UNIT NAME: LIMERICK UNIT 1
 2. REPORTING PERIOD: DECEMBER, 1992
 3. LICENSED THERMAL POWER(MWT): 3293
 4. NAMEPLATE RATING (GROSS MWE): 1138
 5. DESIGN ELECTRICAL RATING (NET MWE): 1055
 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 1092
 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 1055

NOTES: THERE WAS ONE LOAD DROP
 GREATER THAN 20% FOR RECIRC.
 MOTOR GENERATOR SET BRUSH
 CHANGE AND HPCI LEAK REPAIR

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE):
 10. REASONS FOR RESTRICTIONS, IF ANY:

	THIS MONTH	YR-TO-DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744	8,784	60,624
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	6,240.4	47,549.2
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	744.0	6,116.3	46,558.2
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	2,400,475	19,744,549	141,733,465
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	796,610	6,475,200	45,976,140
18. NET ELECTRICAL ENERGY GENERATED (MWH)	767,553	6,229,061	44,040,517

