



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609-2000

O. J. "Ike" Zeringue  
Vice President, Browns Ferry Nuclear Plant

MAR 11 1993

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Dear Sir:

TVA - BROWNS FERRY NUCLEAR PLANT (BFN) UNITS 1, 2, AND 3 - DOCKET NOS. 50-259, 260, AND 296 - FACILITY OPERATING LICENSE DPR-33, 52, AND 68 - LICENSEE EVENT REPORT LER 50-259/93002

The enclosed report provides details concerning an unplanned diesel generator start. The diesel generator auto-started on undervoltage following an unexpected trip of a shutdown bus feeder breaker during maintenance.

This report is submitted in accordance with 10 CFR 50.73(a)(2)(iv) as a condition that resulted in manual or automatic actuation of an engineered safety feature.

Sincerely,

O. J. Zeringue

Enclosure  
cc: See page 2

190023

9303190193 930311  
PDR ADOCK 05000259  
S PDR

*JE27*

U.S. Nuclear Regulatory Commission

MAR 11 1993

cc (Enclosure):

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, Georgia 30339

Paul Krippner  
American Nuclear Insurers  
Town Center, Suite 300S  
29 South Main Street  
West Hartford, Connecticut 06107

NRC Resident Inspector  
Browns Ferry Nuclear Plant  
Route 12, P.O. Box 637  
Athens, Alabama 35609-2000

Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Suite 2900  
Atlanta, Georgia 30323

Thierry M. Ross  
U.S. Nuclear Regulatory Commission  
One White Flint, North  
11555 Rockville Pike  
Rockville, Maryland 20852