



ENTERGY

Entergy Operations, Inc.
P.O. Box 756
Port Gibson, MS 39150
Tel 601 437 6408

March 15, 1993

W. T. Cottle
Vice President
Operations
Grand Gulf Nuclear Station

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-29
Monthly Operating Report

GNRO-93/00030

Gentlemen:

In accordance with the requirement of Technical Specification 6.9.1.10, Entergy Operations is providing the Monthly Operating Report for Grand Gulf Nuclear Station Unit 1 for February 1993.

It has been found recently that the "net electrical energy generation" data for the years of 1990 and 1991 and the month of January 1992 as reported to the NRC are not consistent with the existing correct interpretation of the definition.

During 1990, 1991 and January 1992, Entergy Operations reported negative net generation for outages or startups/shutdowns. The reporting of negative numbers resulted from switching sources for data collection. Previously GGNS had used switchboard logs, but chose to switch to the computerized data acquisition system maintained by the system dispatcher for better accuracy. This system automatically accounted for negative net generation values.

Cumulative Electrical Energy Generation is corrected below:

<u>Year</u>	<u>Value Previously Report (MWe-h)</u>	<u>Corrected Value (MWe-h)</u>
1990	41,141,999	41,160,124
1991	50,260,715	50,293,057
1992	58,431,863	58,467,924

9303190379 930315
PDR ADOCK 05000416
R PDR

JE24

March 15, 1993
GNRO-93/00030
Page 2 of 3

Capacity Factors are also affected by this correction. The corrected year end results are reported below.

	<u>Year</u>	<u>Previously Reported Value (%)</u>	<u>Corrected Value (%)</u>
Unit Capacity Factory (Using MDC Net)	1990	74.0	74.2
	1991	91.1	91.2
Unit Capacity Factor (Using DER Net)	1990	67.6	67.8
	1991	83.3	83.4

If you have any questions or require additional information, please contact this office.

Yours truly,

WTC/CG

WTC/TMC/cg

attachments: 1. Operating Status
 2. Average Daily Power Level
 3. Unit Shutdown and Power Reduction

cc: Mr. R. H. Bernhard (w/a)
 Mr. D. C. Hintz (w/a)
 Mr. R. B. McGehee (w/a)
 Mr. N. S. Reynolds (w/a)
 Mr. H. L. Thomas (w/o)

Mr. Stewart D. Ebner (w/a)
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30323

Mr. P. W. O'Connor, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop 13H3
Washington, D.C. 20555