Wisconsin Electric
POWER COMPANY

231 W Michigan, PO Box 2046, Milwaukee, WI 53201-2046 (414) 221-2345

VPNPD-93- 062
NRC-93- 037

March 9, 1993

Document Control Desk
U. S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301
ADDENDUM TO TECHNICAL SPECIFICATION CHANGE REQUEST 162, MODIFICATIONS TO TECHNICAL SPECIFICATIONS SECTION 15.1.3.A.3, "COMPONENTS REQUIRED FOR REDUNDANT DECAY HEAT REMOVAL CAPABILITY"
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

On February 26, 1993, we submitted the subject Technical Specification Change Request. During review of our submittal, we discovered that the phrase "in an 8 hour period" had been inadvertently omitted from proposed Specification 15.3.1.A.3.a.(4)(a). The proposed wording should read:

(a) "All reactor coolant pumps and residual heat removal pumps may be deenergized for up to 1 hour in an 8 hour period provided:"

To resolve this discrepancy, we are forwarding revised Technical Specification page 15.3.1-2 along with the remainder of the pages previously submitted. Please replace the Technical Specification pages included with our February 26, 1993, submittal with the attached pages. Please note that our February 26, 1993, transmittal letter, safety evaluation, and no significant hazards consideration are consistent with the above wording.

We apologize for any inconvenience this may have caused.

Sincerely,

Bob Link
Vice President
Nuclear Power

Subscribed and sworn to before me this 9th day of March, 1993.

Notary Public, State of Wisconsin

My Commission expires 10-27-96.

A001

170056

Enclosures

cc: NRC Resident Inspector
NRC Regional Administrator
Public Service Commission of WI

15.3 LIMITING CONDITIONS FOR OPERATION

15.3.1 REACTOR COOLANT SYSTEM

Applicability

Applies to the operating status of the Reactor Coolant System.

Objective

To specify those limiting conditions for operation of the Reactor Coolant System which must be met to ensure safe reactor operation.

Specification

A. OPERATIONAL COMPONENTS

1. Coolant Pumps*

a. When the reactor is critical, except for tests, at least one reactor coolant pump shall be in operation.

(1) Reactor power shall not be maintained above 3.5% of rated power unless both reactor coolant pumps are in operation.

(2) If either reactor coolant pump ceases operating, immediate power reduction shall be initiated under administrative control as necessary to reduce power to less than 3.5% of rated power.

(3) If both reactor coolant pumps cease operating and power is greater than 3.5% of rated power, but less than 10% of rated power, reactor shutdown will commence immediately and verify the reactor trip breakers are opened within one hour.

b. When the reactor is subcritical and the average reactor coolant temperature is greater than 350°F, except for tests, at least one reactor coolant pump shall be in operation.

(1) Both reactor coolant pumps may be deenergized provided:

a. No operations are permitted that would cause dilution of the reactor coolant system boron concentration,

b. Core outlet temperature is maintained at least 10°F below saturation temperature, and

c. The reactor trip breakers are open.

st one reactor coolant pump or residual heat removal system in operation when a reduction is made in the boron con- of the reactor coolant.

or shall be operable whenever the average rea is above 350°F.

undant Decay Heat Removal Capability*

ure less than 350°F and greater than decay heat removal methods listed

op A, its associated steam ge coolant pump

B, its associated steam ge olant pump

es are in the reactor