



Tennessee Valley Authority, Post Office Box 2000, Sevier-Dale, Tennessee 37629-2000

Robert A. Fenech
Vice President, Sequoyah Nuclear Plant

March 18, 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - LICENSEE EVENT REPORT
(LER) 50-327/93003

The enclosed LER provides details concerning an automatic turbine trip followed by a reactor trip resulting from the inadvertent tripping of the main generator exciter field breaker. This event is being reported in accordance with 10 CFR 50.73(a)(2)(iv) as an event that resulted in the automatic actuation of engineered safety features, including the reactor protection system.

Sincerely,

Robert A. Fenech

Enclosure
cc: See page 2

250058

9303250143 930318
PDR ADOCK 05000327
S PDR

U.S. Nuclear Regulatory Commission
Page 2
March 18, 1993

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339-3064

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-0199