



GPU Nuclear Corporation
Route 441 South
P.O. Box 480
Middletown, Pennsylvania 17057-0480
(717) 944-7621
Writer's Direct Dial Number:

(717) 948-8005

March 19, 1993
C311-93-2032

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Three Mile Island Nuclear Station, Unit 1, (TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request (TSCR) No. 207
RPV Pressure and Temperature (PT) Limits

In accordance with 10 CFR 50.4(b)(1), enclosed is Technical Specification Change Request No. 207.

Also enclosed is the Certificate of Service for this request certifying service to the chief executives of the township and county in which the facility is located, as well as the designated official of the Commonwealth of Pennsylvania, Bureau of Radiation Protection.

The purpose of this TSCR is to request that the TMI-1 Technical Specifications Section 3.1.2, regarding reactor vessel pressurization heatup and cooldown limitations, and Sections 3.1.12.1 through 3, and 4.5.2.1.c.1, regarding PORV operability and HPI testing as they relate to low temperature overpressurization (LTOP) protection, be revised to extend the period of applicability from 10 EFPY to 32 EFPY, which is beyond the present licensed expiration date based on 90% availability.

In anticipation of your request we have enclosed Technical Specification Section 3.1.2 Reference No. 6 (Topical Report TR 095, Rev. 0).

Pursuant to 10 CFR 50.91(a)(1), enclosed is our analysis, applying the standards in 10 CFR 50.92 to make a determination of no significant hazards considerations. As stated, above, pursuant to 10 CFR 50.91(a), we have provided a copy of this letter, the proposed change in Technical Specifications, and our analyses of significant hazards considerations to Richard R. Janati, the designated representative of the Commonwealth of Pennsylvania.

260001


9303290084 930319
PDR ADDCK 05000289
PDR

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

Adol
1/1

The existing TMI-1 Technical Specification heatup and cooldown limits are applicable for plant operation to ten (10) EFPY. GPU Nuclear requests issuance of this amendment by August 1, 1993 to allow sufficient time for implementation prior to the plant exceeding 10 EFPY.

Sincerely,



T. G. Broughton
Vice President and Director, TMI-1

YN\plp

Enclosures: (1) Technical Specification Change Request No. 207
(2) Certificate of Service for Technical Specification Change Request No. 207
(3) Technical Specification Section 3.1.2 Reference No. 6 Topical Report TR 095, Rev. 0

cc: Administrator Region I
TMI Senior Resident Inspector
TMI-1 Senior Project Manager