



NIAGARA MOHAWK POWER CORPORATION / NINE MILE POINT, P.O. BOX 63, LYCOMING, NY 13093 / TELEPHONE (315) 349-2882

B. Ralph Sylvia
Executive Vice President
Nuclear

March 22, 1993
NMP2L 1373

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C.

Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed is the proposed change to the Technical Specifications set forth in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed change involves no significant hazards consideration pursuant to 10CFR § 50.92 are included as Attachment B.


The proposed Technical Specification change contained herein represents revisions to Section 6.9.1.9, "Core Operating Limits Report." Section 6.9.1.9 is being proposed for revision to incorporate the SAFER/GESTR-LOCA methodology approved by the Staff for accident analyses. Also, the proposed amendment contains revisions to Bases Section 3/4.2 to reflect the addition of the SAFER/GESTR-LOCA methodology as well as editorial changes. Discussion of these editorial changes is included in the supporting information, but since they are unrelated to the proposed Technical Specification changes, they are not addressed in the Affidavit or the Significant Hazards Analysis. In addition, the enclosed revised Bases page B3/4 2-4 does not reflect changes contained in Niagara Mohawk's Application for Amendment dated February 27, 1993. Niagara Mohawk requests approval of this amendment by October 15, 1993, to support restart from the upcoming refueling outage.

9303290209 930322
PDR ADOCK 05000410
PDR

1001

Pursuant to 10CFR § 50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analysis regarding no significant hazards to the appropriate state representative.

Very truly yours,



B. Ralph Sylvia
Exec. Vice President-Nuclear

TDF/pr
Attachment
003657GG

xc: Regional Administrator
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Mr. W. L. Schmidt, Senior Resident Inspector
Ms. Donna Ross
Division of Policy Analysis
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, NY 12223
Records Management