

Duke Power Company
McGuire Nuclear Station
12700 Hagers Ferry Road
Huntersville, NC 28078-8985

(704)875-4000



DUKE POWER

April 2, 1993


U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: McGuire Nuclear Station Unit 1
Docket No. 50-369
Licensee Event Report 369/93-01

Gentlemen:

Pursuant to 10 CFR 50.73 Sections (a) (1) and (d), attached is Licensee Event Report 369/93-01 concerning a Technical Specification required surveillance not being performed because of a test circuit wiring error due to a vendor fabrication deficiency. This report is being submitted in accordance with 10 CFR 50.73 (a) (2) (i). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,


T.C. McMeekin

TLP/bcb

Attachment

xc: Mr. S.D. Ebnetter
Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, GA 30323

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, GA 30339

Mr. Tim Reed
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Mr. P.K. Van Doorn
NRC Resident Inspector
McGuire Nuclear Station

9304060147 930402
PDR ADOCK 05000369
S PDR

JE22