



NIAGARA MOHAWK POWER CORPORATION / NINE MILE POINT, P.O. BOX 63, LYCOMING, NY 13093 / TELEPHONE (315) 349-2882

B. Ralph Sylvia
Executive Vice President
Nuclear

NMP2L 1374
March 30, 1993

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to the Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed are the proposed changes to the Technical Specifications in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B.

The proposed Technical Specification changes contained herein represent revisions to Specification 4.8.1.1.2.e.4 and 4.8.1.1.2.e.8, "AC Sources - Operating." These changes will separate the requirements for the 24-hour run of the emergency diesel generators from the Loss of Off-Site Power (LOOP) Test. These changes are consistent with the requirements in the Improved Standard Technical Specifications, NUREG-1434, issued September 28, 1992. The NRC has found similar changes at McGuire (dated May 6, 1987) and Grand Gulf Nuclear Stations (dated December 6, 1988) to be acceptable. In order to support the upcoming Nine Mile Point Unit 2 Refueling Outage, approval of these changes is requested by September 1, 1993.

060080


003249LL

9304070233 930330
PDR ADDCK 05000410
P PDR

ADD 1

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazard considerations to the appropriate state representative.

Sincerely,



B. Ralph Sylvia
Exec. Vice President-Nuclear

MC/sek
003249LL

Attachments

xc: Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223
Records Management