

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)

NIAGARA MOHAWK POWER CORPORATION)

Nine Mile Point Nuclear Station Unit No. 2)

Docket No. 50-410

APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE


Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of the Facility Operating License No. NPF-69, hereby requests that Technical Specifications 4.8.1.1.2.e.4 and 4.8.1.1.2.e.8 set forth in Appendix A to the License be amended. The proposed changes have been reviewed in accordance with Section 6.5 of the Technical Specifications.

The proposed Technical Specification changes are set forth in Attachment A to this application. These changes will separate the requirements for the 24-hour run of the emergency diesel generators from the Loss of Off-Site Power Test. The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analyses which demonstrate that the proposed changes involve no significant hazards considerations pursuant to 10CFR50.92 are included as Attachment B.

Wherefore, applicant respectfully requests that Appendix A to Facility Operating License No. NPF-69 be amended in the form attached hereto as Attachment A.


NIAGARA MOHAWK POWER CORPORATION

By


B. Ralph Sylva

Executive Vice President-Nuclear

Subscribed and sworn to before
me on this 29 day of 1993 (March)


NOTARY PUBLIC

BEVERLY W. RIPKA
Notary Public State of New York
Qual. in Oswego Co. No. 4644879
My Commission Exp. Mar 31, 1994

9304070238 930330
PDR ADOCK 05000410
P PDR

003249LL