

Neil S. "Buzz" Carns
Vice President
Nuclear Generation

April 2, 1993
NMP2L 1375

United States Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69
(TAC No. M85168)

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits revised pages 3/4 3-33, 3/4 3-34, B3/4 3-1, B3/4 3-2, B3/4 3-2a, B3/4 3-4, B3/4 3-4a and B3/4 3-8 for the proposed Technical Specification amendment dated December 7, 1992. These pages have been revised to clarify and provide bases for operator actions during surveillance and repair of instrument channels. This revision will further strengthen the prevention of "Loss of Function" for the Initiation and Actuation Instrumentation. The revision to the wording of the allowable out-of-service times does not alter the original meaning or intent of the General Electric Licensing Topical Reports or the BWROG Owners' Group clarifications. This revision has been reviewed in accordance with Section 6.5 of the Technical Specification and no changes to the No Significant Hazards Consideration are required. Also, index page xvi has been added to reflect the above changes.

This change was discussed with the Nine Mile Point Unit 2 Project Manager, Mr. J. E. Menning and Mr. C. S. Schulten on April 1, 1993.

Should you have any questions or comments on this transmittal, do not hesitate to contact us.

Sincerely,



Mr. N. S. Carns
Vice President - Nuclear Generation

WCD/lmc
Attachments

xc: Mr. T. T. Martin, Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Ms. Donna Ross

Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, NY 12223

Records Management

9304120116 930402
PDR ADOCK 05000410
P PDR

100021

A001
111