

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

April 5, 1993

JOHN D. SIEBER
Senior Vice President and
Chief Nuclear Officer
Nuclear Power Division

(412) 393-5255
Fax (412) 643-8069

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Emergency Preparedness Plan

In accordance with 10 CFR 50.54(q), we are providing notification of a change to the Beaver Valley Power Station (BVPS) Emergency Preparedness Plan. Based on the review of the Unusual Event declared at BVPS on November 28, 1992, we are deleting Unusual Event INDICATOR 2 of implementing procedure EPP/I-1, Recognition and Classification of Emergency Conditions, TAB 19 "Security Compromise":

"Total loss of the alarm monitoring and card reader control systems (including back-up CPU) as reported by the Security Shift Administrator."

This indicator was found to be overly conservative, due to the low level of significance relative to plant safety. Deletion of this INDICATOR from TAB 19 for both BV-1 and BV-2 was approved by our Onsite Safety Committee on January 14, 1993.

We have reviewed this change and determined that it does not decrease the effectiveness of the Emergency Preparedness Plan and the Plan, as changed, continues to meet the standards of 10 CFR 50.47(b) and the requirements of 10 CFR 50 Appendix E. This event is, and will remain, reportable under the provisions of 10 CFR 73.55 as a one-hour reportable notification if compensatory measures are not in place within ten minutes.

It is important to recognize that this change to TAB 19 does not alter the BVPS Physical Security Plan. Compensatory measures applicable to this equipment failure remain available when required without modification.

120083

9304130300 930405
PDR ADOCK 05000334
F PDR




AD45 '0

Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Emergency Preparedness Plan
Page 2

If you have any questions, please contact R. K. Brosi, Manager
Emergency Preparedness at (412) 393-5767.

Sincerely,


J. D. Sieber

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. G. E. Edison, Project Manager
Mr. E. C. McCabe, NRC Region I