



NIAGARA MOHAWK POWER CORPORATION / 301 PLAINFIELD ROAD, SYRACUSE, N.Y. 13212 / TELEPHONE (315) 474-1511

April 7, 1993  
NMP2L 1377

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555


Re: Nine Mile Point Unit 2  
Docket No. 50-410  
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to the Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed are the proposed changes to the Technical Specifications set forth in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included in Attachment B.

The proposed Technical Specification changes contained herein represent revisions to Specification 3.1.5, "Standby Liquid Control System." These changes will remove the requirement for the Standby Liquid Control System to be OPERABLE in OPERATIONAL CONDITION 5 (Refueling) with any control rod withdrawn. These changes are consistent with the requirements in the Improved Standard Technical Specifications, NUREG-1434, issued September 28, 1992. In order to support the upcoming Nine Mile Point Unit 2 refueling outage, approval of this Application is requested by September 1, 1993.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazards consideration to the appropriate state representative.

Sincerely,  
  
C. D. Terry  
Vice President  
Nuclear Engineering

MC/sek  
003584LL

xc: Regional Administrator, Region I  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. R. A. Capra, Director, Project Directorate I-1, NRR  
Mr. J. E. Menning, Project Manager, NRR  
Ms. Donna Ross  
Division of Policy Analysis and Planning  
New York State Energy Office  
Agency Building 2  
Empire State Plaza  
Albany, NY 12223  
Records Management

130062

9304130321 930407  
PDR ADOCK 05000410  
P PDR

ADD 1