Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY
SENIOR VICE PRESIDENT

TELEPHONE
714-458-4400

April 13, 1993

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: **Docket Nos. 50-361 and 50-362**
Amendment Application Nos. 132 and 116
Change to Technical Specification 3/4.8.1,
"A. C. Sources"
San Onofre Nuclear Generating Station
Units 2 and 3

Reference: 1) November 25, 1991 letter from Harold B. Ray (SCE) to Document Control Desk (NRC), Subject: Docket Nos. 50-361 and 50-362, Amendment Application Nos. 112 and 96, Changes to Technical Specifications 3/4.7.8 and 3/4.8.1, San Onofre Nuclear Generating Station, Units 2 and 3

Provided in Enclosure 1 are Amendment Application Nos. 132 and 116 to Facility Operating Licenses NPF-10 and NPF-15, respectively, for the San Onofre Nuclear Generating Station, Units 2 and 3. These Amendment Applications consist of Proposed Change Number (PCN) 427. PCN 427 is a request to revise Technical Specification (TS) 3/4.8.1, "A. C. Sources." This proposed change will provide a one-time exception to TS 4.8.1.1.1.a to allow replacement of the 480V transformers B04X and B06X during the Units 2 and 3 Cycle 7 refueling outages.

PCN 363 (Reference 1) and this PCN 427 both request a change to page 3/4 8-2 of TS 4.8.1.1.1.a for Unit 3. Therefore, a markup of page 3/4 8-2 which includes the changes from both PCN 363 and PCN 427 is provided as Enclosure 2.

Southern California Edison (SCE) requests NRC approval of this amendment request in time for use during the Unit 2 Cycle 7 refueling outage, which is scheduled to begin in June 1993.

A001
1/1

9304150194 930413
PDR ADOCK 05000361
P PDR

If you would like additional information regarding this Technical Specification change request, please let me know.

Sincerely,

Harold B. Ray

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2&3
M. B. Fields, NRC Project Manager, San Onofre Units 2 and 3
H. Kocol, California Department of Health Services