



Ralph E. Beedle
Executive Vice President
Nuclear Generation

April 15, 1993
JPN-93-028

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Proposed Change to the Technical Specifications
Revision of Table 4.7-2 (JPTS-89-038 and JPTS-92-009)

REFERENCE: 1. NRC letter, D. LaBarge to J. C. Brons,
dated November 14, 1989, (JAF-89-379)
transmits Amendment 143.

Dear Sir:

This application for an amendment to the James A. FitzPatrick Technical Specifications makes four changes to Table 4.7-2, "Exception to Type C Tests." The first adds system numbers to the valve identification numbers for seven control rod drive containment isolation valves to be consistent with valve identifiers in the Technical Specifications, and clarifies the penetration arrangements. There is no change to the valves themselves or to the penetrations. The second change removes valves 10MOV-57 and 10MOV-67 from the table because they are not containment isolation valves as defined by the current FitzPatrick licensing basis. The third change adds valves 10RHR-729A and 10RHR-729B to the table to exempt them from Type C testing based on the current FitzPatrick licensing basis. Fourthly, three errors introduced in Amendment 143 (Reference 1) are corrected.

The signed original of the Application for Amendment to Operating License is enclosed for filing. Attachments I and II to this application contain the proposed changes to the Technical Specifications and the associated Safety Evaluation.

190147


9304210277 930415
PDR ADDCK 05000333
P PDR

ADD 11

A copy of this application and the associated attachments are being provided to the designated New York State official in accordance with 10 CFR 50.91.

If you have any questions, please contact Mr. J. A. Gray, Jr.

Very truly yours,



Ralph E. Beedle

att: as stated

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Brian C. McCabe
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14 B2
Washington, DC 20555

Ms. Donna Ross
New York State Energy Office
2 Empire State Plaza
16th Floor
Albany, NY 12223