

April 15, 1993  
LIC-93-0103

Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247  
402/636-2000

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

- References:
1. Docket No. 50-285
  2. NRC Bulletin 92-01, dated June 24, 1992
  3. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated July 29, 1992 (LIC-92-225R)
  4. NRC Generic Letter 92-08, dated December 17, 1992


Gentlemen:

SUBJECT: THERMO-LAG 330-1 FIRE BARRIERS - GENERIC LETTER 92-08 RESPONSE

NRC Bulletin 92-01 concerned "Failure of Thermo-Lag 330 Fire Barrier System to Maintain Cabling in Wide Cable Trays and Small Conduits Free From Fire Damage." Reference 3 provided the Omaha Public Power District (OPPD) response to this bulletin.

Generic Letter 92-08 requested additional information from licensees to verify that Thermo-Lag 330-1 fire barriers comply with NRC requirements. OPPD has reviewed appropriate fire protection documentation for Fort Calhoun Station (FCS). No Thermo-Lag 330-1 barriers are relied upon (a) to meet 10 CFR 50.48, to achieve physical independence of electrical systems, (b) to meet a condition of the plant operating license, or (c) to satisfy a licensing commitment. Thermo-Lag 330-1 barriers are not used to protect safety related systems or components. No other reporting requirements of Generic Letter 92-08 are therefore applicable to FCS.

Sincerely,



W. G. Gates  
Vice President

WGG/tcm

Attachment

c: LeBoeuf, Lamb, Leiby & MacRae  
S. D. Bloom, NRC Project Manager  
J. L. Milhoan, NRC Regional Administrator, Region IV  
R. P. Mullikin, NRC Senior Resident Inspector

9304230129 930415  
PDR ADOCK 05000285  
P PDR

230001

Employment with Equal Opportunity  
Male/Female

AC29

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of  
Omaha Public Power District  
(Fort Calhoun Station Unit No. 1)

Docket No. 50-285

AFFIDAVIT

W. G. Gates, being duly sworn, hereby deposes and says that he is a Vice President of the Omaha Public Power District; that as such he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached response to Generic Letter 92-08 dated December 17, 1992 concerning Thermo-Lag 330-1 Fire Barriers; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information, and belief.

W. G. Gates  
W. G. Gates  
Vice President

STATE OF NEBRASKA )  
COUNTY OF DOUGLAS ) ss

Subscribed and sworn to before me, a Notary Public in and for the State of Nebraska on this 15 day of April, 1993.

Carol J. Kelley  
Notary Public

