

PHILADELPHIA ELECTRIC COMPANY

LIMERICK GENERATING STATION

P. O. BOX 2300

SANATOGA, PA 19464-2300

(215) 327-1200 EXT. 2000

J. DOERING, JR.
PLANT MANAGER
LIMERICK GENERATING STATION

April 22, 1993
Docket No. 50-353
License No. NPF-85

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: Licensee Event Report
Limerick Generating Station - Unit 2

This LER reports a Unit 2 reactor SCRAM, an Automatic Reactor Protection System actuation, resulting from a closure of the Main Turbine Stop Valves, and an automatic actuation of the Primary Containment and Reactor Vessel Isolation Control System (an Engineered Safety Feature). The cause of this event was air entrained in the Main Turbine Electro Hydraulic Control system.

| | |
|------------------|---|
| Reference: | Docket No. 50-353 |
| Report Number: | 2-93-005 |
| Revision Number: | 00 |
| Event Date: | March 26, 1993 |
| Report Date: | April 22, 1993 |
| Facility: | Limerick Generating Station P.O. Box 2300, Sanatoga, PA 19464-2300 |

This LER is being submitted pursuant to the requirements of 10 CFR 50.73(a)(2)(iv).

Very truly yours,

J. G. Muntz
for J. Doering

DMS:cah

cc: T. T. Martin, Administrator, Region I, USNRC
N. S. Perry, USNRC Senior Resident Inspector, LGS

260078

9304260263 930422
PDR ADOCK 05000353
S PDR

JEPP
11