



Westinghouse  
Electric Corporation

Energy Systems

Box 355  
Pittsburgh Pennsylvania 15230-0355

April 12, 1993  
ET-NRC-93-3862

Document Control Desk  
US Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Mr. James E. Richardson, Director  
Division of Engineering Technology

Subject: Revised Catawba Unit 1 Steam Line Break Steam Generator (SG) Leakage Evaluation

Dear Mr. Richardson:

Attached is a single copy of Revision 1 to a report entitled "NRC Requested Catawba Unit 1 Steam Generator Leakage Evaluation" (Proprietary). This report responds to the NRC request at the Catawba Unit 1 SG tube interim plugging criterion meeting of April 1, 1993 to provide SLB leak rate analyses based on assuming an average leak rate for the measured data independent of bobbin probe voltage. This report was revised from that provided with ET-NRC-93-3861 at the request of the NRC staff to contain an additional SLB leakage rate calculation. All revisions to the original report are identified by a vertical line in the right hand margin of the affected pages. This report contains information which is proprietary to Westinghouse Electric Corporation. Accordingly, we request that this information be withheld from public disclosure.

We will comply with the requirements of 10 CFR 2.790 to provide proprietary and non-proprietary versions of the above material together with an affidavit as soon as the proprietary and non-proprietary versions have been prepared. We will submit the total required number of copies of the proprietary and non-proprietary versions of the information and the required affidavit at that time.

In the meantime, we have provided sufficient copies for your information and use. M. P. Siemien, Esq. of the NRC Office of the General Counsel, has advised Westinghouse that she concurs with this procedure.

We expect to be able to fully comply with the requirements for the proprietary and non-proprietary versions of the information and an accompanying affidavit within four weeks.

Very truly yours,

Nicholas J. Liparulo, Manager  
Nuclear Safety and Regulatory Activities

GWW/cld  
Enclosure

CLD297:GWW/041293

9304260280 930421  
PDR ADOCK 05000413  
P PDR