


Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone 205 877-7122

C. K. McCoy
Vice President, Nuclear
Vogtle Project

April 22, 1993



Docket No. 50-424

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT
SPECIAL REPORT 1-93-3
NUMBER OF STEAM GENERATOR
TUBES PLUGGED DURING 1R4

Georgia Power Company is submitting this special report of the number of steam generator tubes plugged during the Unit 1 fourth refueling outage (1R4) per the requirements of the Vogtle Electric Generating Plant Technical Specifications, sections 4.4.5.5.a and 6.8.2.

After inservice inspection completion on April 3, 1993, four (4) tubes were plugged in steam generator No. 3. Only one of these tubes met or exceeded the Technical Specification limit for wall thinning (40 percent). The remainder were plugged as a precautionary measure. Complete inspection results will be submitted within 12 months per the Technical Specification 4.4.5.5.b. requirement.

Sincerely,

C.K. McCoy
C. K. McCoy

CKM/NJS

xc: Georgia Power Company
Mr. W. B. Shipman
Mr. M. Sheibani
NORMS

U. S. Nuclear Regulatory Commission
Mr. S. D. Ebner, Regional Administrator
Mr. D. S. Hood, Licensing Project Manager, NRR
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

260014

9304270197 930422
PDR ADDCK 05000424
S PDR

ADD 1/0