



Northern States Power Company

414 Nicollet Mall  
Minneapolis, Minnesota 55401-1927  
Telephone (612) 330-5500

April 26, 1993

10 CFR Part 50  
Section 50.73

U S Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT  
Docket Nos. 50-282 License Nos. DPR-42  
50-306 DPR-60

Auto-start of No. 121 Cooling Water Pump on Low  
Header Pressure While Aligned for Safeguards Operation

The Licensee Event Report for this occurrence is attached. In the report, we made one new NRC commitment:

The surveillance procedures for testing diesel-driven cooling water pumps will be revised to clarify the instructions for disposition of the header valves.

This event was reported via the Emergency Notification System in accordance with 10 CFR Part 50, Section 50.72, on March 25, 1993. Please contact us if you require additional information related to this event.

Roger O Anderson  
Director  
Licensing and Management Issues

c: Regional Administrator - Region III, NRC  
NRR Project Manager, NRC  
Senior Resident Inspector, NRC  
Kris Sanda, State of Minnesota

Attachment

300050

9305030049 930426  
PDR ADOCK 05000282  
S PDR

*Handwritten initials/signature*