



Wisconsin
Electric
POWER COMPANY

231 W Michigan, PO Box 2046, Milwaukee, WI 53201

(414) 224-2345

VPNPD-93-091
NRC-93-054

10 CFR 50.73

April 27, 1993

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Gentlemen:

DOCKET 50-301
LICENSEE EVENT REPORT 93-002-00
REACTOR TRIP DURING TURBINE TRIP TESTING
POINT BEACH NUCLEAR PLANT, UNIT 2

Enclosed is Licensee Event Report 93-002-00 for Point Beach Nuclear Plant, Unit 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(iv), "The licensee shall report...any event or condition that resulted in manual or automatic actuation of any Engineered Safety Feature (ESF), including the Reactor Protection System (RPS)."

This report describes a Unit 2 reactor trip which occurred during performance of the thrust bearing trip test portion of Technical Specification Test TS-4A, "Turbine Trip Test (Monthly), Unit 2."

Please contact us if any further information is required.

Sincerely,

Bob Link
Vice President
Nuclear Power

DAW/jg

Enclosure

cc: NRC Resident Inspector
NRC Regional Administrator, Region III

030000

9305040011 930427
PDR ADDCK 05000301
S PDR

A subsidiary of Wisconsin Energy Corporation