

ATTACHMENT 2  
LICENSE AMENDMENT APPLICATION, LCR 93-01, NLR-N93050  
VENTING THROUGH THE HARDENED TORUS VENT  
FACILITY OPERATING LICENSE NPF-57  
HOPE CREEK GENERATING STATION  
DOCKET NO. 50-354

TECHNICAL SPECIFICATION PAGE WITH PEN AND INK CHANGES

The following Technical Specifications for  
Facility Operating License No. NPF-57 are affected  
by this license amendment request:

<u>Technical Specification</u>	<u>Page</u>
3.11.2.8	3/4 11-18
4.11.2.8	3/4 11-18

## RADIOACTIVE EFFLUENTS

### VENTING OR PURGING

#### LIMITING CONDITION FOR OPERATION

3.11.2.8 VENTING or PURGING of the Mark I containment drywell shall be through either the reactor building ventilation system or the filtration, recirculation and ventilation system.\*

APPLICABILITY: Whenever the containment is vented or purged.

ACTION:

- a. With the requirements of the above specification not satisfied, suspend all VENTING and PURGING of the drywell.
- b. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.11.2.8 The containment shall be determined to be aligned for VENTING or PURGING through ~~either~~ the reactor building ventilation system, ~~or~~ the filtration, recirculation and ventilation system within 4 hours prior to start of and at least once per 12 hours during VENTING or PURGING of the drywell.

OR THE HARDENED TORUS VENT

\* Following Type A Integrated Leakage Rate Testing, the Mark I containment drywell may be vented through the hardened torus vent.