

Unit 1

Marked Pages

RADIOACTIVE EFFLUENTS

BASES

3/4.11.1.3 LIQUID WASTE TREATMENT

This specification deleted. Refer to the Offsite Dose Calculation Manual.

3/4.11.1.4 LIQUID HOLDUP TANKS

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than ~~ten times~~ the limits of 10 CFR Part 20, Appendix B (to paragraphs 20.1001 - 20.2401), Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area.

3/4.11.2 GASEOUS EFFLUENTS

3/4.11.2.1 DOSE RATE

This specification deleted. Refer to the Offsite Dose Calculation Manual.

ADMINISTRATIVE CONTROLS

=====

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.1601(a) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit.* Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. A health physics qualified individual (i.e., qualified in radiation protection procedures) with a radiation dose rate monitoring device who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the facility Health Physics Supervisor.

6.12.2 In addition to the requirements of 6.12.1, areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mrem^{but less than 500 rads} shall be provided with locked doors to prevent unauthorized entry, and the keys shall be maintained under the administrative control of the Shift Foreman on duty and/or health physics supervision. Doors shall remain locked except during periods of access by personnel under an approved Radiation Work Permit which shall specify the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. For individual areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose in excess of 1000 mrem**, that are located within large areas, such as PWR containment, where no enclosure exists for purposes of locking, and no enclosure can be reasonably constructed around the individual areas, then that area shall be roped off, conspicuously posted and a flashing light shall be activated as a warning device. In lieu of the stay time specification of the RWP, direct or remote (such as use of closed circuit TV cameras) continuous surveillance may be made by personnel qualified in radiation protection procedures to provide positive exposure control over the activities within the area.

— but less than 500 rads***

* Health Physics personnel or personnel escorted by Health Physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are following plant radiation protection procedures for entry into high radiation areas.

** Measurement made at 30 cm from the radiation source or from any surface that the radiation penetrates.

*** Measurement made at 1 meter from the radiation source or from any surface that the radiation penetrates.

Unit 1

Typed Pages

RADIOACTIVE EFFLUENTS

BASES

.....

3/4.11.1.3 LIQUID WASTE TREATMENT

This specification deleted. Refer to the Offsite Dose Calculation Manual.

3/4.11.1.4 LIQUID HOLDUP TANKS

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than the limits of 10 CFR Part 20, Appendix B (to paragraphs 20.1001 - 20.2401), Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area.

3/4.11.2 GASEOUS EFFLUENTS

3/4.11.2.1 DOSE RATE

This specification deleted. Refer to the Offsite Dose Calculation Manual.

ADMINISTRATIVE CONTROLS

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.1601(a) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit.* Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. A health physics qualified individual (i.e., qualified in radiation protection procedures) with a radiation dose rate monitoring device who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the facility Health Physics Supervisor.

6.12.2 In addition to the requirements of 6.12.1, areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mrem but less than 500 rads shall be provided with locked doors to prevent unauthorized entry, and the keys shall be maintained under the administrative control of the Shift Foreman on duty and/or health physics supervision. Doors shall remain locked except during periods of access by personnel under an approved Radiation Work Permit which shall specify the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. For individual areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose in excess of 1000 mrem** but less than 500 rads*** that are located within large areas, such as PWR containment, where no enclosure exists for purposes of locking, and no enclosure can be reasonably constructed around the individual

* Health Physics personnel or personnel escorted by Health Physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are following plant radiation protection procedures for entry into high radiation areas.

** Measurement made at 30 cm from the radiation source or from any surface that the radiation penetrates.

*** Measurement made at 1 meter from the radiation source or from any surface that the radiation penetrates.

ADMINISTRATIVE CONTROLS

areas, then that area shall be roped off, conspicuously posted and a flashing light shall be activated as a warning device. In lieu of the stay time specification of the RWP, direct or remote (such as use of closed circuit TV cameras) continuous surveillance may be made by personnel qualified in radiation protection procedures to provide positive exposure control over the activities within the area.

Farley Unit 2
Revised Proposed Changed
Technical Specification Pages

Revised Page

B 3/4 11-2*

6-22*

6-22a**

* Supersedes proposed changed technical specification page submitted by Southern Nuclear Operating Company letter dated December 17, 1992.

** New proposed changed technical specification page.

Unit 2

Marked Pages

RADIOACTIVE EFFLUENTS

BASES

=====

3/4.11.1.3 LIQUID WASTE TREATMENT

This specification deleted. Refer to the Offsite Dose Calculation Manual.

3/4.11.1.4 LIQUID HOLDUP TANKS

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than ~~ten times~~ the limits of 10 CFR Part 20, Appendix B (to paragraphs 20.1001 - 20.2401), Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area.

3/4.11.2 GASEOUS EFFLUENTS

3/4.11.2.1 DOSE RATE

This specification deleted. Refer to the Offsite Dose Calculation Manual.

ADMINISTRATIVE CONTROLS

=====

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.1601(a) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit.* Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. A health physics qualified individual (i.e., qualified in radiation protection procedures) with a radiation dose rate monitoring device who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the facility Health Physics Supervisor.

6.12.2 In addition to the requirements of 6.12.1, areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mrem^{but less than 500 rads} shall be provided with locked doors to prevent unauthorized entry, and the keys shall be maintained under the administrative control of the Shift Foreman on duty and/or health physics supervision. Doors shall remain locked except during periods of access by personnel under an approved Radiation Work Permit which shall specify the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. For individual areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose in excess of 1000 mrem**, that are located within large areas, such as PWR containment, where no enclosure exists for purposes of locking, and no enclosure can be reasonably constructed around the individual areas, then that area shall be roped off, conspicuously posted and a flashing light shall be activated as a warning device. In lieu of the stay time specification of the RWP, direct or remote (such as use of closed circuit TV cameras) continuous surveillance may be made by personnel qualified in radiation protection procedures to provide positive exposure control over the activities within the area.

— but less than 500 rads***

* Health Physics personnel or personnel escorted by Health Physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are following plant radiation protection procedures for entry into high radiation areas.

** Measurement made at 30 cm from the radiation source or from any surface that the radiation penetrates.

*** Measurement made at 1 meter from the radiation source or from any surface that the radiation penetrates.

Unit 2

Typed Pages

RADIOACTIVE EFFLUENTS

BASES

=====

3/4.11.1.3 LIQUID WASTE TREATMENT

This specification deleted. Refer to the Offsite Dose Calculation Manual.

3/4.11.1.4 LIQUID HOLDUP TANKS

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than the limits of 10 CFR Part 20, Appendix B (to paragraphs 20.1001 - 20.2401), Table 2, Column 2, at the nearest potable water supply and the nearest surface water supply in an unrestricted area.

3/4.11.2 GASEOUS EFFLUENTS

3/4.11.2.1 DOSE RATE

This specification deleted. Refer to the Offsite Dose Calculation Manual.

ADMINISTRATIVE CONTROLS

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.1601(a) of 10 CFR 20, each high radiation area in which the intensity of radiation is greater than 100 mrem/hr but less than 1000 mrem/hr shall be barricaded and conspicuously posted as a high radiation area and entrance thereto shall be controlled by requiring issuance of a Radiation Work Permit.* Any individual or group of individuals permitted to enter such areas shall be provided with or accompanied by one or more of the following:

- a. A radiation monitoring device which continuously indicates the radiation dose rate in the area.
- b. A radiation monitoring device which continuously integrates the radiation dose rate in the area and alarms when a preset integrated dose is received. Entry into such areas with this monitoring device may be made after the dose rate level in the area has been established and personnel have been made knowledgeable of them.
- c. A health physics qualified individual (i.e., qualified in radiation protection procedures) with a radiation dose rate monitoring device who is responsible for providing positive control over the activities within the area and shall perform periodic radiation surveillance at the frequency specified by the facility Health Physics Supervisor.

6.12.2 In addition to the requirements of 6.12.1, areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose greater than 1000 mrem but less than 500 rads shall be provided with locked doors to prevent unauthorized entry, and the keys shall be maintained under the administrative control of the Shift Foreman on duty and/or health physics supervision. Doors shall remain locked except during periods of access by personnel under an approved Radiation Work Permit which shall specify the dose rate levels in the immediate work area and the maximum allowable stay time for individuals in that area. For individual areas accessible to personnel with radiation levels such that a major portion of the body could receive in one hour a dose in excess of 1000 mrem** but less than 500 rads*** that are located within large areas, such as PWR containment, where no enclosure exists for purposes of locking, and no enclosure can be reasonably constructed around the individual

* Health Physics personnel or personnel escorted by Health Physics personnel shall be exempt from the RWP issuance requirement during the performance of their assigned radiation protection duties, provided they are following plant radiation protection procedures for entry into high radiation areas.

** Measurement made at 30 cm from the radiation source or from any surface that the radiation penetrates.

*** Measurement made at 1 meter from the radiation source or from any surface that the radiation penetrates.

ADMINISTRATIVE CONTROLS

=====

areas, then that area shall be roped off, conspicuously posted and a flashing light shall be activated as a warning device. In lieu of the stay time specification of the RWP, direct or remote (such as use of closed circuit TV cameras) continuous surveillance may be made by personnel qualified in radiation protection procedures to provide positive exposure control over the activities within the area.