

In the Matter of the Facility Operating License)
of)
PUBLIC SERVICE COMPANY OF COLORADO)

9305170050 930507
PDR ADDCK 05000267
W PDR

In the Matter of the Facility Operating License)
of)
Public Service Company of Colorado Fort St.) Docket No. 50-267
Vrain Unit No. 1)

My commission expires 11-29, 1995

ATTACHMENT 1

TO P-93045

SUMMARY OF PROPOSED CHANGE

SUMMARY OF PROPOSED CHANGE

DTS Section

Summary of Change

Design Feature 4.3

Revise PCR V Leakage Prevention section to allow blind flanges to be removed from PCR V outlet coolant thermocouple penetrations, during use of push rod assemblies for thermocouple removal.