



NIAGARA MOHAWK POWER CORPORATION / NINE MILE POINT, P.O. BOX 63, LYCOMING, NY 13093 / TELEPHONE (315) 349-2882

B. Ralph Sylvia
Executive Vice President
Nuclear

May 7, 1993
NMP2L 1383

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed are the proposed changes to the Technical Specifications set forth in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B.

The proposed Technical Specification changes contained herein represent an addition to Section 3/4.10, "Special Test Exceptions." The addition of Specification 3/4.10.7, "Inservice Leak and Hydrostatic Testing," permits remaining in OPERATIONAL CONDITION 4 with reactor coolant temperatures > 200°F to facilitate inservice leak and hydrostatic testing. These changes are consistent with the "Improved Technical Specifications," NUREG-1433, issued September 28, 1992. A similar amendment has been previously approved for Edwin I. Hatch, Unit 2. In order to support the upcoming refueling outage, approval of this license amendment is requested by September 1, 1993.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazard considerations to the appropriate state representative.

Very truly yours,

B. R. Sylvia
Exec. Vice President - Nuclear

MGM/sek
003576LL
Enclosures

xc: Mr. T. T. Martin, Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Records Management
Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223

140098

9305170242 930507
PDR ADDCK 05000410
P PDR

ADD 1/1