



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

May 14, 1993
PY-CEI/NRR-1648 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Gentlemen:

Attached is the April 1993 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,



Robert A. Stratman

RAS:DWC:ss

Attachment

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Region III
Director, Office of Resource Management
Ohio EPA

Operating Companies
Cleveland Electric Illuminating
Company
190
9305180434 930430
PDR ADOCK 05000440
R PDR

124
1/1

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

April 1, 1993 - April 30, 1993

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO.	50-440
UNIT	Perry-1
DATE	05/14/93
Contact	H. L. Hegrat
Telephone	(216)259-3737

MONTH April 1993

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0	31	N/A
16	0		

Operating Data Report

UNIT: PERRY-1
DATE: 05/14/93

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: April 1993
3. Utility Contact: H. L. Hegrat (216) 259-3737
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
None
10. Power Level To Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	This Month	Yr-to-Date	Cumulative
12. Hours In Reporting Period	719.0	2,879.0	47,771.0
13. Hours Reactor Was Critical	0.0	676.8	33,989.0
14. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
15. Hours Generator On-Line	0.0	551.4	32,830.6
16. Unit Reserve Shutdown Hours	0.0	0.0	0.0
17. Gross Thermal Energy (MWH)	0.0	1,741,878	112,231,849
18. Gross Electrical Energy (MWH)	0.0	586,737	38,602,734
19. Net Electrical Energy (MWH)	0.0	542,530	36,662,247
20. Unit Service Factor	0.0%	19.2%	68.7%
21. Unit Availability Factor	0.0%	19.2%	68.7%
22. Unit Capacity Factor (Using MDC Net)	0.0%	16.2%	66.6%
23. Unit Capacity Factor (Using DER Net)	0.0%	15.8%	64.4%
24. Unit Forced Outage Rate	100.0%	60.6%	10.0%
25. Forced Outage Hours	719.0	847.6	3,638.7
26. Shutdowns Scheduled Over Next 6 Months (Type, Date and Duration of Each): <u>None</u>			
27. If Shut Down at end of Report Period, Estimated Date of Startup: <u>May 20, 1993</u>			

CODED/7488/SS

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH April 1993

DOCKET NO. 50-440
 UNIT NAME Perry - 1
 DATE 05/14/93
 CONTACT H. L. Hegrat
 TELEPHONE (216) 259-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
93-02	03/26/93	F	719.0	A	2	93-010	KG	PSX	The unit remained shutdown throughout the month due to the Service Water (P41) pipe rupture on March 26, 1993.

SUMMARY: During April, 1993, Perry-1 began and ended the month shutdown due to the service water pipe rupture on March 26, 1993.

¹ F: Forced
 S: Scheduled

² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training &
 License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

⁴ Exhibit G-Instructions for
 Preparation of Data Entry
 Sheets for Licensee Event
 Report (LER) File (NUREG1022)

⁵ Exhibit I-Same Source