



NIAGARA MOHAWK POWER CORPORATION/NINE MILE POINT, P.O. BOX 63, LYCOMING, NY 13093/TELEPHONE (315) 349-2882

B. Ralph Sylvia
Executive Vice President
Nuclear

May 18, 1993
NMP2L 1385

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an application for amendment to the Nine Mile Point Unit 2 Operating License NPF-69. Also enclosed is the proposed change to the Technical Specifications in Appendix A of the above mentioned license. Supporting information and analyses demonstrating that the proposed change involves no significant hazards considerations pursuant to 10CFR50.92 are included in Appendix B.

The proposed Technical Specification change contained herein represents a revision to Specification 4.6.1.2.a to allow a one time extension of the required test interval for the Primary Containment Integrated Leakage Rate Test (Type A), to bring this test in line with the 10-year plant inservice inspection. The NRC has found similar extensions at Grand Gulf (dated February 22, 1993) and Salem 2 (dated January 17, 1993) nuclear stations to be acceptable. In order to support the upcoming Nine Mile Point Unit 2 Refueling Outage, approval of this application is requested by September 1, 1993.

Pursuant to 10CFR50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazard considerations to the appropriate state representative.

Sincerely,

B. Ralph Sylvia

Exec. Vice President - Nuclear

MC/mls

Attachments

xc: Mr. T. T. Martin, Regional Administrator, Region I
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. R. A. Capra, Director, Project Directorate I-1, NRR
Mr. J. E. Menning, Project Manager, NRR
Ms. Donna Ross

Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223

Records Management

9305260247 930518
PDR ADDCK 05000410
P PDR

240020

AD17