

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of)

Niagara Mohawk Power Corporation)

Docket No. 50-410

Nine Mile Point Unit 2)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. NPF-69, hereby requests that section 3/4.6.1.2 of the Technical Specifications set forth in Appendix A to the License be amended. This proposed change has been reviewed in accordance with section 6.5 of the Technical Specifications.

The proposed Technical Specification change is set forth in Attachment A to this application. The proposed amendment requests a revision of the Technical Specification to allow a one time extension of the required test interval for the Primary Containment Integrated Leakage Rate Test as specified in specification 4.6.1.2.a to bring this test in line with the 10-year plant inservice inspection. The proposed change will not authorize any change in the types of effluents or in the authorized power level of the facility. Supporting information and analyses which demonstrate that the proposed change involve no significant hazards considerations pursuant to 10CFR50.92, are included as Attachment B.

Wherefore, applicant respectfully requests that Appendix A to facility operating License No. NPF-69 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By

B. Ralph Sylvia
B. Ralph Sylvia

Executive Vice President - Nuclear

Subscribed and Sworn to before
me on this 18 day of May

Beverly W. Ripka
NOTARY PUBLIC

BEVERLY W. RIPKA
Notary Public State of New York
Qual. in Oswego Co. No. 4644879
My Commission Exp. Mar 11 2/28/94

9305260249 930518
PDR ADDCK 05000410
P PDR