

D509
Detroit
Edison

Douglas R. Gipson
Senior Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5249

6720
T. Dunning
58FR18118
4/7/93
USNRC
OFFICE OF ADMINISTRATION

'93 MAY 24 P1:31

May 21, 1993
NRC-93-0070

Chief, Rules Review and Directives Branch
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

- Reference:
- 1) Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43
 - 2) General Electric BWR Owners' Group
Topical Report, NEDC-32013P. "System Analyses for
the Elimination of Selected Response Time Testing
Requirements." March 1992 (Proprietary)
 - 3) Detroit Edison letter to NRC, NRC-92-0001, "Proposed
Technical Specification Change (License Amendment)
for Selected Response Time Testing Requirements,"
dated March 27, 1992

Subject: Comments on Proposed Generic Letter on Relocation of
Technical Specification Tables on Instrument Response
Time Limits (58 FR 18118, April 7, 1993)

Detroit Edison appreciates the opportunity to comment on the proposed
Generic Letter (GL) to allow Response Time Testing surveillance limits
to be relocated from the Technical Specifications. In general, we
support the concept that, as far as possible, technical details such
as these should be under the control of the licensee.

The proposed guidance does not address those instrument channels which
are indicated as "NA" (not applicable) in the required response time
column. In addition, other clarifying notes appear in these tables
which help define the time period which is required to be measured.
The GL needs to address how this information should be retained in the
Technical Specifications or if it can be relocated.

The proposed GL indicates that the RTT surveillance requirements
should be modified to add an exemption from RTT for neutron detectors.
The model Technical Specifications of Enclosure 2 of the GL does not
include this change. The model Technical Specifications should be
modified to include the change.

9305270052 930521
PDR ORG NRRB
PDR


Chief, Rules Review and Directives Branch
May 21, 1993
NRC-93-0070
Page 2

Additionally, the BWR Owners' Group has submitted a Topical Report (Reference 2) and Detroit Edison has submitted a license amendment request (Reference 3) to modify or eliminate many RTT requirements. The GL needs to take into account that many requests for RTT requirement changes are likely following NRC staff review of the Topical Report. Confusion can be avoided and resources conserved if this GL is coordinated with the Topical Report review.

In summary, the GL needs to address that the TS response time limit tables contain more information than presently covered by the GL. Also, the GL needs to take into account the industry efforts to reduce the burden of RTT.

If you have any questions, please contact Mr. Glen D. Ohlemacher at (313) 586-4275.

Sincerely,



cc: T. G. Colburn
W. J. Kropp
J. B. Martin
M. P. Phillips
U.S. NRC Document Control Desk
Washington, D. C. 20555