



State of New Jersey
Department of Environmental Protection and Energy
Division of Environmental Safety, Health and Analytical Programs
CN 415
Trenton, NJ 08625-0415

Scott A. Welner
Commissioner

Gerald P. Nicholls, Ph.D.
Director

June 1, 1993

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Gentlemen:


Subject: Oyster Creek Nuclear Generating Station (OCNGS)
Docket No. 50-219
Technical Specification Change Request No. 208
Safety Valve Setpoint Change

On March 3, 1993, GPU Nuclear Corporation, licensee of the Oyster Creek Nuclear Generating Station, submitted the subject amendment to the Nuclear Regulatory Commission (NRC). This Technical Specification Change Request (TSCR) proposes the reduction of the setpoint of the ninth (highest) safety valve from 1230 to 1221 psig.

The New Jersey Department of Environmental Protection and Energy's Bureau of Nuclear Engineering (BNE) reviewed the above amendment in accordance with the requirements of 10CFR50.91(b). Based on this review, the BNE does not have any comments on the proposed change.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,


Kent Tosch, Manager
Bureau of Nuclear Engineering

100035

9306140249 930601
PDR ADDCK 05000219
P PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

A001
1/0

c: Jill Lipoti
Assistant Director, Radiation Protection Programs
N.J. DEPE

A. Dromerick
NRC Sr. Project Manager

D. Vito
NRC Sr. Resident Inspector

M. Laggart, GPU Nuclear