



## Nebraska Public Power District

COOPER NUCLEAR STATION  
P.O. BOX 96, BROWNVILLE, NEBRASKA 68321  
TELEPHONE (402)825-3811  
FAX (402)825-5211

CNSS938686

June 9, 1993

Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Subject: Monthly Operating Status Report for May, Docket No. 50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for May 1993. The report includes Operating Status, Average Daily Unit Power Level, Unit Shutdown Data and a Narrative Summary of Operating Experience.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,

R. L. Gardner  
Plant Manager

RLG:MRE:dls

Enclosures

cc: G. D. Watson w/enclosures  
J. L. Milhoan w/enclosures

140001

9306140318 930531  
PDR ADDCK 05000298  
R PDR

FE24  
11

# OPERATING DATA REPORT

DOCKET NO. 050-0298  
UNIT CNS  
DATE June 9, 1993  
TELEPHONE (402) 825-5766

## OPERATING STATUS

1. Unit Name: Cooper Nuclear Station Notes
2. Reporting Period: May 1993
3. Licensed Thermal Power (MWt): 2381
4. Nameplate Rating (Gross MWe): 836
5. Design Electrical Rating (Net MWe): 778
6. Maximum Dependable Capacity (Gross MWe): 787
7. Maximum Dependable Capacity (Net MWe): 764
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:  
\_\_\_\_\_  
\_\_\_\_\_
9. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
10. Reasons For Restriction, If Any: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

	This Month	Yr.-to-Date	Cumulative
11. Hours in Reporting Period	<u>744.0</u>	<u>3,623.0</u>	<u>165,840.0</u>
12. Number of Hours Reactor Was Critical	<u>0.0</u>	<u>1,526.0</u>	<u>126,493.0</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>1,526.0</u>	<u>124,734.9</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0.0</u>	<u>3,405,552.0</u>	<u>256,249,516.0</u>
17. Gross Electric Energy Generated (MWH)	<u>0.0</u>	<u>1,134,134.0</u>	<u>83,125,116.0</u>
18. Net Electric Energy Generated (MWH)	<u>0.0</u>	<u>1,096,791.0</u>	<u>80,255,107.0</u>
19. Unit Service Factor	<u>0.0</u>	<u>42.1</u>	<u>75.2</u>
20. Unit Availability Factor	<u>0.0</u>	<u>42.1</u>	<u>75.2</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0.0</u>	<u>39.6</u>	<u>63.3</u>
22. Unit Capacity Factor (Using DER Net)	<u>0.0</u>	<u>38.9</u>	<u>62.2</u>
23. Unit Forced Outage Rate	<u>100.0</u>	<u>32.8</u>	<u>4.8</u>
24. Shutdown Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End of Report Period, Estimated Date of Startup: June 19, 1993
26. Units In Test Status (Prior to Commercial Operation):
 

Forecast	Achieved
INITIAL CRITICALITY	_____
INITIAL ELECTRICITY	_____
COMMERCIAL OPERATION	_____

# AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 050-0298  
UNIT CNS  
DATE June 9, 1993  
TELEPHONE (402) 825-5766

MONTH May 1993

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>0</u>	17	<u>0</u>
2	<u>0</u>	18	<u>0</u>
3	<u>0</u>	19	<u>0</u>
4	<u>0</u>	20	<u>0</u>
5	<u>0</u>	21	<u>0</u>
6	<u>0</u>	22	<u>0</u>
7	<u>0</u>	23	<u>0</u>
8	<u>0</u>	24	<u>0</u>
9	<u>0</u>	25	<u>0</u>
10	<u>0</u>	26	<u>0</u>
11	<u>0</u>	27	<u>0</u>
12	<u>0</u>	28	<u>0</u>
13	<u>0</u>	29	<u>0</u>
14	<u>0</u>	30	<u>0</u>
15	<u>0</u>	31	<u>0</u>
16	<u>0</u>		

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

110

DOCKET NO.	050-0298
UNIT NAME	Cooper Nuclear Station
DATE	June 9, 1993
COMPLETED BY	M. R. Eash
TELEPHONE	(402) 825-5766

REPORT MONTH May 1993[illegible]

- |   |                           |   |   |   |  |   |  |
|---|---------------------------|---|---|---|--|---|--|
| 1 | F: Forced<br>S: Scheduled | 2 | Reason:<br>A - Equipment Failure (Explain)<br>B - Maintenance or Test<br>C - Refueling<br>D - Regulatory Restriction<br>E - Operator Training & License Examination<br>F - Administrative<br>G - Operational Error (Explain)<br>H - Other (Explain) | 3 | Method:<br>1 - Manual<br>2 - Manual Scram<br>3 - Automatic Scram<br>4 - Continued<br>5 - Reduced Load<br>6 - Other | 4 | Exhibit G - Instructions for<br>Preparation of Data Entry<br>Sheets for Licensee Event<br>Report (LER) File (NUREG-0161) |
|   |                           |   |   |   |  | 5 | Exhibit I - Same Source  |

**OPERATIONS NARRATIVE  
COOPER NUCLEAR STATION**

May 1993

The EOC 15 Refueling Outage began March 5 and continued through the month of May.

Maintenance and repair activities continued through the month of May.

Cooper Station had 0.0 percent capacity factor for the month of May.