

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-269/270/287

REG: OREILLY J P
NRC

ORG: PARKER W O
DUKE.PWR


DOCDATE: 04/17/78
DATE RCVD: 04/12/78

DOCTYPE: LETTER NOTARIZED: NO

COPIES RECEIVED
LTR 1 ENCL 1

SUBJECT:
FORWARDING LICENSEE EVENT RPT (RO 50-269/78-10) ON 03/24/78 CONCERNING
KEOWEE HYDRO UNIT 1 WAS TAKEN OUT-OF-SVC AND KEOWEE UNIT 2, THE STANDBY
EMERGENCY PWR SOURCE, WAS NOT VERIFIED OPERABLE WITHIN THE TECH SPEC LIMIT OF
8 HOURS. W/ENCL.

PLANT NAME: OCONEE - UNIT 1
OCONEE - UNIT 2
OCONEE - UNIT 3

REVIEWER INITIAL: XJM
DISTRIBUTER INITIAL: 

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****


NOTES:

1. M. CUNNINGHAM - ALL AMENDMENTS TO PSAR AND CHANGES TO TECH SPECS

INCIDENT REPORTS
(DISTRIBUTION CODE A002)

FOR ACTION: BR CHIEF/SEID**W/4 ENCL

INTERNAL:

 REG. FILE**W/ENCL
I & E**W/2 ENCL
SCHROEDER/IPPOLITO**W/ENCL
NOVAK/CHECK**W/ENCL
KNIGHT**W/ENCL
HANAUER**W/ENCL
EISENHUT**W/ENCL
SHAO**W/ENCL
KREGER/J. COLLINS**W/ENCL
K. SEYFRIT/IE**W/ENCL

NRC PDR**W/ENCL
MIPC**W/3 ENCL
HOUSTON**W/ENCL
EEB**W/ENCL
BUTLER**W/ENCL
TEDESCO**W/ENCL
BAER**W/ENCL
VOLLMER/BUNCH**W/ENCL
POBA**W/ENCL

EXTERNAL:

LEDR'S
WALHALLA, SC**W/ENCL
TIC**W/ENCL
NSIC**W/ENCL
ACRS CAT B**W/13 ENCL

POOR
ORIGINAL

DISTRIBUTION: LTR 45 ENCL 45
SIZE: 1P+1P+1P

 CONTROL NBR: ~~11720087~~

***** THE END *****

8001100603

S

DUKE POWER COMPANY

STEAM PRODUCTION DEPT.

GENERAL OFFICES

422 SOUTH CHURCH STREET

CHARLOTTE, N. C. 28242

P. O. BOX 2178

TELEPHONE: AREA 704
373-4011

April 7, 1978

REGULATORY DOCKET FILE COPY

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Suite 1217
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

RE: Oconee Units 1, 2 and 3
Docket No. 50-269, -270, and -287

Dear Mr. O'Reilly:

Pursuant to Sections 6.2 and 6.6.2 of the Oconee Nuclear Station Technical Specifications, please find attached Reportable Occurrence Report RO-269/78-10.

Very truly yours,

William O Parker Jr
William O. Parker, Jr. *by WAK*

KRW/vmb

Attachment

cc: Director, Office of Management Information
and Program Control

781030037

A002
5/11