

Pollution Control Auth.

7. 29211

George M. James

DATE OF DOCUMENT:

Nov. 19, 1970

DATE RECEIVED

Feb. 1, 1971

NO.:

400

LTR.

MEMO:

REPORT:

OTHER:

ORIG.:

CC:

OTHER:

ACTION NECESSARY ☐

CONCURRENCE ☐

DATE ANSWERED:

NO ACTION NECESSARY ☐

COMMENT ☐

BY:

FILE CODE:

50-269 50-270 50-287 (ENVIRO FILE)

CLASSIF:

U

POST OFFICE

REG. NO:

DESCRIPTION: (Must Be Unclassified)

Ltr trans the following:

REFERRED TO

DATE

RECEIVED BY

DATE

Long

2-2-71

w/4 cys for ACTION

DISTRIBUTION:

Reg File(3)(1 as docket)

AEC PDR(3)(1 as docket)

Henderson

Felton

Klecker

Shaper-OGC-Ba-P-506-A

DiSummo

Boyd

DeYoung

E. Price SLR

N. Dube

P. Howe(2)

Compliance(2)

Morris/Schroeder

DL

ENCLOSURES:

Ltr fm S.C. Dept of Health adv permit to construct cooling water system for Oconee Nuclear Station has been approved

(1 cy encl rec'd)

REMARKS:

*NOTE ABOVE HAND CARRIED & REC'D IN REG RECORDS 1-28-71. CYS MADE FM ORIG & RET TO PAUL BARTON, DUKE POWER CO. REC'D FOR DOCKETING 2-1-71

U.S. ATOMIC ENERGY COMMISSION

MAIL CONTROL FORM FORM AEC-3265 (8-60)

☆ U.S. GOVERNMENT PRINTING OFFICE: 1970-382-148

POOR
ORIGINAL

8001140 808 A

50-267-210-287
P4D
South Carolina Pollution Control Authority

AUTHORITY MEMBERS

HERBERT W. TURNER CHARLESTON
CHAIRMAN
I. N. MILLER, M.D. COLUMBIA
FRANK MIXSON GEORGETOWN
K. E. POWERS SIMPSONVILLE
LIAM M. BRICE, JR. YORK
F. LAU GREENWOOD
MARION SHIVER, JR. CAMDEN



HUBERT J. WEBB, PH.D.
EXECUTIVE DIRECTOR

OWEN BUILDING
1321 LADY STREET P. O. BOX 11628
Columbia, South Carolina 29211

AUTHORITY MEMBERS
EX-OFFICIO

E. KENNETH AYCOCK, M.D. COLUMBIA
JAMES W. WEBB COLUMBIA
CLAIR P. GUESS, JR. COLUMBIA
BOB HICKMAN COLUMBIA
LEWIS E. HENDRICKS COLUMBIA
J. BONNER MANLY COLUMBIA

AREA CODE 803
TELEPHONE: 758-2915

November 19, 1970

Duke Power Company
P. O. Box 2178
Charlotte, North Carolina 28201

Re: story

POOR
ORIGINAL

Attention: Mr. W. S. Lee
Vice President, Engineering

Re: Oconee Nuclear Station
Oconee County
Cooling Water

Dear Sir:

After careful study of plans and data submitted by you, we are happy to forward herewith our Permit to Construct the cooling water system for your Oconee Nuclear Station.

Please let us know when the work is completed so that we may make a pre-operational inspection.

By direction of H. J. Webb, Ph.D., Executive Director, Pollution Control Authority.

Very truly yours,

George A. Rhame

George A. Rhame
Assistant Director

GAR/dkw



409

OV

South Carolina State Board of Health
Division of Sanitary Engineering
AND
Pollution Control Authority
COLUMBIA, SOUTH CAROLINA

November 19, 1970

11-19-70

Duke Power Company
P. O. Box 2178
Charlotte, North Carolina 28201

Regulatory

Oconee Nuclear Station

The following project has this day been approved for construction as complying with the Rules and Regulations of the State Board of Health and the South Carolina Pollution Control Authority:
OCONEE COUNTY: Intake and discharge structures for condenser water for the Oconee Nuclear Station.

Water to be taken near the bottom of Lake Keowee from the Little River side and returned to the Toxaway River side.

Maximum water use to be 3,040 mgd.

Temperature requirements of the South Carolina Water Quality Standards to be met at all times.

POOR
ORIGINAL

Approved:

E. Kenneth Aycock, M.D.

George A. Rhame
XXXXXX G. A. Rhame, Asst.
for H. J. Webb, Ex.

S. C. State Board of Health File No. _____

Pollution Control Construction Permit No. 1727

GAR/dkw

C.C. County Health Dept., PCA Lab, Mr. Jefferson C. Fuller, Army Engrs.