

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C | T | M | N | S | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 1 | 1 | 5

7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32

CONT

0	1	REPORT SOURCE															DUCKET NUMBER															EVENT DATE															REPORT DATE														
7	8	L	6	0	5	0	0	0	3	3	6	7	0	1	0	1	8	1	8	0	1	2	8	8	1	9																																			
		60	61									63							74	75						80																																			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0]2] During routine power operation, the output from steam generator differential pressure

transmitter, PDT-121B, failed low causing a low flow trip on channel B of the Reactor

[6] [8] Protection System. The channel was bypassed and the Unit operated for 8 hours under ]

the Action Statement of Technical Specification 3.3.1.1. Similar Events: None

06 | \_\_\_\_\_

[0] 7 | \_\_\_\_\_

0	5											50	
7	8	9											
												COMP	VALUE

SYSTEM CODE: 09  
 CAUSE CODE: 11  
 CAUSE SUBCODE: 12  
 COMPONENT CODE: 13  
 COMP. SUBCODE: 14  
 VALVE SUBCODE: 15  
 REVISION: 16

(17) JERIRO REPORT NUMBER

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NRC FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER							
B	18	Z	19	Z	20	Z	21	0	0	0	0	N	23	Y	24	A	25	M	2	8	2		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A dirty Knife switch contact caused an open circuit between the differential pressure

1 1 transmitter and the low flow trip bistable resulting in the channel trip. The switch

112 | contacts were cleaned and the switch was returned to service. The switch was manu-

13 | Manufactured by Meter Devices Co.

9 \_\_\_\_\_

80

FACILITY STATUS      % POWER      OTHER STATUS (30)      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION (32)

1 5 8 9 [E] (28) 10 11 12 13 [1 0 0] (29) N/A 44 45 46 [A] (31) Operator Observation 80

ACTIVITY CONTENT  
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)  
[2] (33) [2] (34) N/A 44

LOCATION OF RELEASE (36)  
N/A 45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	N/A	(39)

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	40	N/A

8 9 11 12  
LOSS OF OR DAMAGE TO FACILITY (43)  
TYPE DESCRIPTION  
1 9 Z (42) N/A

8 5 10  
PUBLICITY  
ISSUED DESCRIPTION (45) 8102020 408  
2 0 N (44) N/A  
68 69 80