



435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-6000

July 1, 1981

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Attn: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing
Washington, DC 20555



Reference: Beaver Valley Power Station, Unit No. 1
Docket No. 50-334
NUREG-0737, Item I.C.6 Verifying Performance of Operating
Activities

Gentlemen:

In discussions with Mr. Dennis Chaney of your staff, we have been informed that the interim actions described in our letter to you dated April 1, 1981, are not completely satisfactory to meet the requirements of action item I.C.6 of NUREG-0737.

By September 6, 1981, the Duquesne Light Company will provide independent verification of the correct performance of operating activities on equipment required to prevent or mitigate the consequences of an accident and/or to bring the plant to a safe shutdown condition. This independent verification will be performed by an individual that is fully qualified to perform the verification. This will not necessarily be an individual of the same job class as the individual that performed the activity.

If you have any questions, please contact my office.

Very truly yours,

J. J. Carey
J. J. Carey
Vice President, Nuclear

cc: Mr. D. A. Beckman, Resident Inspector
U.S. Nuclear Regulatory Commission
Beaver Valley Power Station
Shippingport, PA 15077

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

A046
S
1/0