

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M A P P S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58CON'T
0 1 R E P O R T L 6 0 5 0 - 0 2 9 3 7 0 7 2 0 8 1 8 0 8 1 8 8 1 9
7 8 9 REPORT SOURCE 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 On 7/20/81, in performance of surveillance test 8.M.2-1.1, pressure switch PS-261-23A

0 3 was found to be 3 psi over Tech. Spec. limit of - 110 PSIG. The minimum number of

0 4 operable instruments requirements of Tech. Specs. was met. This switch has dual

0 5 functions; on increasing pressure it contributes to auto closure of shutdown cooling

0 6 valves and on decreasing pressure permits manual operation of these valves below

0 7 100 psig.

0 8 9

0 9 I B 11 X 12 Z 13 I N S T R U 14 S 15 Z 16
7 8 9 SYSTEM CODE 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP. SUBCODE 14 VALVE SUBCODE 15

17 L E R / R O E V E N T Y E A R 8 1 0 3 8 0 3 L 0
7 8 9 REPORT NUMBER 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN E 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD X 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER B O G 9 26
33 34 35 36 37 38 39 40 41 42 43 44 45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The switch was re-calibrated to conform to Tech. Spec. setpoint. This setpoint drift

1 1 problem has been the subject of an investigation to determine root cause. The

1 2 results of this investigation is to be the subject of an update to LER 81-036/03L.

1 3

1 4 9

1 5 E 28 1 0 0 29 N.A. B 31 Routine Test
7 8 9 FACILITY STATUS 10 % POWER 11 OTHER STATUS 12 METHOD OF DISCOVERY 13 DISCOVERY DESCRIPTION 14

1 6 Z 33 Z 34 N.A. N.A.
7 8 9 ACTIVITY CONTENT 10 RELEASED OF RELEASE 11 AMOUNT OF ACTIVITY 12 LOCATION OF RELEASE 13

1 7 0 0 0 37 Z 38 N.A.
7 8 9 PERSONNEL EXPOSURES 10 NUMBER 11 TYPE 12 DESCRIPTION 13

1 8 0 0 0 40 N.A.
7 8 9 PERSONNEL INJURIES 10 NUMBER 11 DESCRIPTION 12

1 9 Z 42 N.A.
7 8 9 LOSS OF OR DAMAGE TO FACILITY 10 TYPE 11 DESCRIPTION 12

2 0 N 44 N.A.
7 8 9 PUBLICITY 10 ISSUED 11 DESCRIPTION 12

NRC USE ONLY

8108310133 810818
PDR ADOCK 05000293
S PDR

G. G. Whitney

PHONE: 617-746-7900