



HELPING BUILD ARKANSAS

ARKANSAS POWER & LIGHT COMPANY

P.O. BOX 551 • LITTLE ROCK, ARKANSAS 72203 • (501) 371-4191

March 9, 1979

DONALD A. RUETER
DIRECTOR
TECHNICAL AND
ENVIRONMENTAL SERVICES

1-039-5

Director of Nuclear Reactor Regulation
ATTN: Robert W. Reid, Chief
Division of Operating Reactors
Branch No. 4
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Arkansas Nuclear One-Unit 1
Docket No. 50-313
License No. DPR-51
Fire Protection
(File: 1510, 2040)

Gentlemen:

As committed in our June 15, 1978 letter, attached is the proposed fire test of Cable Penetration Fire Stops installed in metal lath and plaster walls at ANO. The penetrations tested will represent "worst case" conditions.

The proposed test does not include fire stops in concrete floors and concrete and masonry walls. These will be addressed in a separate test to be submitted by August 1, 1979.

To ensure that we have time to perform the fire stop test and make whatever possible modifications may be necessary before the 1980 refueling outage, we request that you review the test and comment as soon as possible.

Very truly yours,

Donald A. Rueter

DAR:MOW:nak

Attachment

7903210-232



AP006 (LTR)
1/10
4 ENCL TO:
FILES (1)
I & E (1)
PLANT SYS
BR (2)