



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

April 8, 1982



Mr. A. Schwencer, Chief
Licensing Branch #2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Unit 1
Revised Reactor Vessel Material
Surveillance Program Withdrawal
Schedule
NRC Docket No. 50-373

Dear Mr. Schwencer:

The purpose of this letter is to transmit a revised Tech Spec Table 4.4.6.1.3-1. This table is being revised because it has come to our attention that the specimen holders are welded closed enclosures. Therefore, it is not realistic to remove samples from the holders. Instead, as shown on the attached revised table, we now propose to remove an entire specimen holder at a time.

If there are any further questions in this matter, please contact this office.

Very truly yours,

C. W. Schroeder 4/9/82

C. W. Schroeder
Nuclear Licensing Administrator

lm

cc: NRC Resident Inspector - LSCS

3850N

Boo!
5/11

8204140113 820408
PDR ADOCK 05000373
A PDR