

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 S C N E E 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32

CON'T

01 R 0 5 0 0 0 2 6 9 7 0 3 2 9 8 2 8 0 4 0 9 8 2 9

REPORT SOURCE 30 31 DOCKET NUMBER 38 39 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During troubleshooting of a low sample flow alarm on the Unit 1 Channel B

03 hydrogen analyzer, the differential pressure regulator for the oxygen supply

04 was found with the diaphragm ruptured. Investigation found 5 of 12 defective

05 regulators. Since the problem was found during functional testing prior to

06 operation of the system it is felt that the health and safety of the public

07 were not affected by this accident.

08

09

SYSTEM CODE I F 11 CAUSE CODE B 12 CAUSE SUBCODE B 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16

LER/RO REPORT NUMBER 17 EVENT YEAR 8 2 SEQUENTIAL REPORT NO. 0 0 1 9 OCCURRENCE CODE 0 1 REPORT TYPE T REVISION NO. 0

ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED Y 22 NPRO-4 FORM BUS. N 23 PRIME COMP. SUPPLIER L 24 COMPONENT MANUFACTURER C 5 3 0 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This incident was apparently caused by a manufacturing deficiency since three

11 of the defective regulators were located in panels which had not been used prior

12 to this incident. The differential pressure regulators will be replaced prior

13 to completion of functional testing and system turnover.

14

15

FACILITY STATUS E 26 % POWER 1 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY CONTENT RELEASED OR RELEASE Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY NA 36 LOCATION OF RELEASE NA 37

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER J. F. Kutzer PHONE: (704) 373-7139

NRC USE ONLY

8204280299