

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

April 23, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 257
NO/JHL:acm
Docket No. 50-339
License No. NPF-7



Gentlemen:

AMENDMENT TO OPERATING LICENSE NPF-7
NORTH ANNA POWER STATION UNIT NO. 2
PROPOSED TECHNICAL SPECIFICATION CHANGE

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment in the form of changes to the Technical Specifications, to Operating License NPF-7 for North Anna Power Station, Unit No. 2. The proposed Technical Specification changes are enclosed.

This proposed change is to modify Technical Specification 3/4.6.3.1, Table 3.6-1 for North Anna Unit No. 2 to reflect the addition and deletion of containment isolation valves. Air-operated trip valves are being replaced with direct-acting solenoid valves to improve post-accident sampling capabilities. Manual isolation valves are being replaced with remotely operated isolation valves in the post-accident containment hydrogen analysis and control equipment. Two isolation valves are being installed to provide containment integrity for the post-accident sampling system containment return line. The upgrade and installation of the containment isolation valves for post-accident sampling meets the requirements for containment isolation integrity as specified in the FSAR. The upgrade and installation of these containment isolation valves satisfies the seismic design criteria for safety related systems. The proposed Technical Specification Change is enclosed in Attachment 1. A discussion of the proposed change is enclosed in Attachment 2.


This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and System Nuclear Safety and Operating Committee. This request was reviewed and approved while the System Nuclear Safety and Operating Committee was still in existence. It has been determined that this request does not involve an unreviewed safety question as defined in 10 CFR 50.59.

A001
s
//
w/check:
\$4000.00

8204280365

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. Since this request involves a safety issue which the staff should be able to determine does not pose a significant hazard consideration for Unit 2, a Class III license amendment fee is required for Unit 2. Accordingly, a voucher check in the amount of \$4000.00 is enclosed in payment of the required fees.

Very truly yours,


R. H. Leasburg

Attachments

1. Proposed Technical Specification Change
2. Discussion of Proposed Technical Specification Change
3. Voucher Check No. 21005 for \$4000.00

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

Vepco

WACHOVIA BANK & TRUST COMPANY N.A.

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA

66-152
631

VOID IF NOT CASHED IN 90 DAYS

PAY FOUR THOUSAND AND 00/100 DOLLARS

03301 26 0021005 00000400000

TO
THE
ORDER
OF
UNITED STATES NUCLEAR
REGULATORY COMMISSION
NUCLEAR REG C DC 20555

BK	CHECK NO	DATE	VENDOR NO	AMOUNT
26	21005	04/23/82	3301	\$4,000.00

03301 26 0021005 00000400000

⑈0290618⑈ ⑆053101529⑆ 3608 088819⑈

John P. ...

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by W. L. Stewart, who is Manager-Nuclear Operations and Maintenance, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 23rd day of April, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. McSee
Notary Public

(SEAL)

M004

ATTACHMENT 1