

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4		5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	---

7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0	1	L	6	0	5	0	-	0	3	2	5	7	0	3	1	9	8	2	8	0	4	1	4	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During plant operation, routine surveillance revealed that primary containment multi-point temperature recorder, 1-CAC-TR-1258, was printing erratically. A similar

0 3 event involving this instrument was reported in LER 1-82-2. This event did not

0 4 affect the health and safety of the public.

0 5

0 6

0 7

Technical Specifications 3.3.5.3, 6.9.1.9b

0	9	I	D	11	E	12	E	13	I	N	S	T	R	U	14	R	15	Z	16
---	---	---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----

7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 Y 24 N 25 B 4 1 5 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event occurred due to fouled electrical contacts in the recorder point select

1 1 relay. The relay contacts were cleaned and the recorder, Model No. 551, was returned

1 2 to service. This instrument is cleaned and inspected every three months and calibrated

1 3 every six months to ensure dependable operation.

1 4

1	5	E	28	0	6	3	29	NA	A	31	Operator Surveillance	32
---	---	---	----	---	---	---	----	----	---	----	-----------------------	----

7 8 9 10 12 13 44 45 46 80
16 Z 33 Z 34 NA NA LOCATION OF RELEASE 36
7 8 9 10 11 44 45 80
17 0 0 0 37 Z 38 NA 39
7 8 9 10 11 12 13 80
18 0 0 0 40 NA 41
7 8 9 10 11 12 80
19 Z 42 NA 43
7 8 9 10 80
20 N 44 8204280491 45 NA
7 8 9 10 80
NRC USE ONLY
7 8 9 10 80

NAME OF PREPARER M. J. Pastva, Jr.

PHONE 919-457-9521