

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40
A L J M F 2										0 0 - 0 0 0 0 0 - 0 0 0										3 4 1 1 1 1 4																			
L										0 5 0 0 0 3 6 4										0 2 2 6 8 2 5 0 3 2 5 8 2																			

At 0440 on 2/26/82 the instrumentation loop associated with LI-474 (S.G. "A" Level Indicator) was declared inoperable when its reading was out of tolerance with the other two level indicator readings. Tech. Spec. section 3.3.2, in part, requires this instrumentation loop to be operable. Tech. Spec. 3.3.2 action statement requirements were met. The health/safety of the public was not affected.

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
I B	E	E	I N S T R U	T	Z
EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.	
8 2	0 1 0	0 3	L	0	
ACTION TAKEN - ACTION	EFFECT ON PLANT	SHUTDOW/METHOD	HOURS	ATTACHMENT SUBMITTED	NRD-4 FORM SUB.
E Z	Z	Z	0 0 0 0	N	N
PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER				
A	B 0 8 0				

This event was caused by the loss of the necessary level in the reference leg while the steam generator was not in service. The reference leg was refilled and upon satisfactory completion of FNP-2-SIP-213.1 (Steam Generator 2A LT-474 Loop Calibration and Functional Test) the instrumentation channel associated with Level Indicator LT-474 was declared operable at 2336 on 2/26/82.

FACILITY STATUS	% POWER	OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION
C	0 0 0	NA	B	Routine Inspection
ACTIVITY	CONTENT	AMOUNT OF ACTIVITY	LOCATION OF RELEASE	
Z	Z	NA	NA	
PERSONNEL EXPOSURES	NUMBER	TYPE	DESCRIPTION	
0 0 0	Z		NA	
PERSONNEL INJURIES	NUMBER	DESCRIPTION		
0 0 0		NA		
LOSS OF OR DAMAGE TO FACILITY	TYPE	DESCRIPTION		
Z		NA		
PUBLICITY	DESCRIPTION			
N		NA		