

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

April 23, 1982



Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No: 254
FR/GLD: sbw
Docket No: 50-338

License No: NPF-4

Gentlemen:

RELOAD INFORMATION FOR CYCLE 4
NORTH ANNA NUCLEAR POWER STATION UNIT NO. 1

North Anna Unit No. 1 is scheduled to complete its third cycle of operation on May 21, 1982 and will go into an outage for refueling. The purpose of this letter is to advise you of our plans for the Cycle 4 reload core and to transmit to you the Core Surveillance Report containing specific power distribution limits applicable for Cycle 4 operation.

The Cycle 4 reload core was analyzed in accordance with the methodology documented in Westinghouse Topical Report WCAP-9272 entitled "Westinghouse Reload Safety Evaluation Methodology." The results of this analysis indicated that no key analysis parameters would become more limiting during Cycle 4 operations than the values assumed in the currently applicable safety analysis. Further, the analysis demonstrated that the current Technical Specifications, as approved through Operating License Amendment No. 38, are appropriate and require no additional changes.

A detailed review of the Westinghouse methodology, analysis techniques and results has been conducted by our technical staff. In addition, a review has been performed by both the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control staff. It has been determined that no unreviewed safety questions as defined in 10 CFR 50.59 will exist as a result of the Cycle 4 reload core.

8204290365

A001
1/1


VIRGINIA ELECTRIC AND POWER COMPANY TO Mr. Harold R. Denton

Attachment 1 provides the Core Surveillance Report containing the specific Cycle 4 values for Fxy and the axial power distribution surveillance limit, Pm. This report is being provided as required by North Anna Unit No. 1 Technical Specification 6.9.1.10 and is based on the recently approved total peaking factor (FQ) limit of 2.14.

Verification of the reload core will be performed through a startup physics testing program. Unless otherwise indicated, this program will be consistent with the program proposed for North Anna Unit No. 2 in my letter to you dated April 8, 1982, Serial No. 204.

This letter is provided for your information. However, should you have questions, please contact us at your earliest convenience.

Very truly yours,



R. H. Leasburg

Attachment

(1) Core Surveillance Report for North Anna 1, Cycle 4

cc: Mr. James P. O'Reilly, Regional Administrator
Office of Inspection and Enforcement
Region II

ATTACHMENT 1

Core Surveillance Report

North Anna 1, Cycle 4

TABLE 1
-----NORTH ANNA UNIT 1, CYCLE 4 CORE SURVEILLANCE LIMITS, $FQ = 2.14$

- I. The F-XY limits for RATED THERMAL POWER within specific core planes shall be:
1. $F_{xy-RTP} \leq 1.71$ for all core planes containing bank "D" control rods, and
 2. $F_{xy-RTP} \leq 1.60$ for all unrodded core planes.
- II. The axial power distribution surveillance threshold power level shall be:
1. $P_m = 100\%$ of RATED THERMAL POWER.

NORTH ANNA UNIT 1, CYCLE 4

MAXIMUM ($F_Q^T \cdot P_{Rel}$) vs. AXIAL CORE HEIGHT
DURING NORMAL CORE OPERATION

