

CONTROL BLOCK:

--	--	--	--	--	--

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 7 8
N E C P R 14 2 15 0 0 - 0 0 0 0 0 - 0 0 25 3 26 4 5 6 7 8 9 30 4 57 CAT 58 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

0 1 7 8
REPORT SOURCE L 6 61 0 5 0 0 0 2 9 8 7 68 0 3 2 4 8 2 74 8 75 0 4 2 2 8 2 80 9

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While operating at 87% power, performance of S.P. 6.3.5.1 resulted in uncovering a
0 3 | downcomer causing drywell to torus dP to be reduced below T.S. 3.7.E requirements. dP
0 4 | remained at 0.95 PSID or higher and was restored to > 1 PSID within one hour. No ad-
0 5 | verse consequences from the standpoint of public health and safety resulted from this
0 6 | occurrence.
0 7 |

0	8											80										
7	8	9	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE					
0	9		C	F	11	B	12	A	13	X	X	X	X	X	X	14	Z	15	Z	16		
7	8		9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25			
17		LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.										
		8	2	21	22	—	23	0	0	7	24	25	26	27	28	29	L	30	31	0	32	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						
F	18	A	19	Z	20	Z	21	0	0	0	0	N	23	N	24	Z	25	Z	9	9	9	26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Drywell/torus dP reduced below T.S. when downcomer in torus uncovered by flow wave

1 1 while running RHR full flow test. dP restored. Design change to redirect test line

1 2 return flow to be accomplished May 1982.

1 3

1 4

FACILITY STATUS (1) 5 (E) (28) 0 8 7 (29) NA (30) OTHER STATUS
 METHOD OF DISCOVERY (B) (31) Operator Observation (32) DISCOVERY DESCRIPTION
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
 (1) 6 (Z) (33) (Z) (34) NA
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)
 (1) 7 (0) (0) (0) (37) (Z) (38) NA
 PERSONNEL INJURIES NUMBER DESCRIPTION (41)
 (1) (1) (0) (0) (0) (40) NA
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)
 (1) 9 (Z) (47) NA
 PUBLICITY ISSUED DESCRIPTION (45)
 (2) 0 (N) (44) NA

8204300380

NRC USE ONLY

NAME OF PREPARER Keith Wire

PHONE: 402-825-3811