

UPDATE REPORT

PREVIOUS REPORT DATE 7-31-81

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	3	1	7	0	7	0	1	8	1	3	0	4	2	3	8	2	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During surveillance testing, torus atmosphere sampling line isolation va
0 3 | lve SV-8108A would not close. Redundant isolation valve SV-8107A was ope
0 4 | rable and was placed in the closed position complying with Tech. Spec. 3
0 5 | .7.D.2. No previous similar occurrences with SV-8108A have been recorded
0 6 |
0 7 |
0 8 |

7 8

SYSTEM CODE 9 10 (11)

CAUSE CODE 11 (12)

CAUSE SUBCODE 12 (13)

COMP. SUBCODE 19 (15)

VALVE SUBCODE 20 (16)

COMPONENT CODE 12 13 14 15 16 17 18

SEQUENTIAL REPORT NO. 24 25 26

OCCURRENCE CODE 28 29

REPORT TYPE 30 (31)

REVISION NO. 32

LER/RO REPORT NUMBER (17) 21 22

ACTION TAKEN 33 34 (18)

FUTURE ACTION 35 36 (19)

EFFECT ON PLANT 37 38 (20)

SHUTDOWN METHOD 39 40 (21)

HOURS 41 42 43 44 (22)

ATTACHMENT SUBMITTED 45 46 (23)

NPRO-4 FORM SUB. 47 48 (24)

PRIME COMP. SUPPLIER 49 50 (25)

COMPONENT MANUFACTURER 51 52 53 54 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Solenoid Valve SV-8108A nonclosure was caused by rust in the mechanical
11 portion of the solenoid which impeded proper solenoid operation. The sol
12 enoid was dismantled and cleaned. SV-8108A was then tested and found sa
13 tisfactory. SV-8108A is a Target Rock model 72V-003 solenoid valve. A sa
14 mple of similar valves was inspected and found satisfactory.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (1) 5 (2) E (3) 28 (4) 10 (5) 6 (6) 3 (7) 29 NA (8) 44

METHOD OF DISCOVERY (9) B (10) 31 Surveillance Test (11) 45

DISCOVERY DESCRIPTION (12) 32

OTHER STATUS (13) 30

ACTIVITY CONTENT RELEASED OF RELEASE (14) 1 (15) 6 (16) Z (17) 33 (18) 10 (19) Z (20) 34 NA (21) 44

AMOUNT OF ACTIVITY (22) 35

LOCATION OF RELEASE (23) 36

PERSONNEL EXPOSURES NUMBER (24) 1 (25) 7 (26) 0 (27) 0 (28) 0 (29) 37 (30) Z (31) 38 NA (32) 44

DESCRIPTION (33) 39

PERSONNEL INJURIES NUMBER (34) 1 (35) 4 (36) 0 (37) 0 (38) 0 (39) 40 NA (40) 44

DESCRIPTION (41) 40

LOSS OF OR DAMAGE TO FACILITY TYPE (42) 1 (43) 9 (44) Z (45) 42 NA (46) 44

DESCRIPTION (47) 43

PUBLICITY ISSUED (48) 2 (49) 0 (50) N (51) 44 NA (52) 44

DESCRIPTION (53) 45

8204300472

NRC USE ONLY

NAME OF PREPARER Kimuel L. Hill

PHONE: 319-851-5611