

**Detroit
Edison**

Harry Tauber
Vice President
Engineering and Construction

2000 Second Avenue
Detroit, Michigan 48226
(313) 237-8000



April 26, 1982
EF2 - 56,943

Mr. R. L. Tedesco
Assistant Director for Licensing
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Tedesco:

- References: (1) Enrico Fermi Atomic Power Plant, Unit 2
NRC Docket No. 50-341
- (2) Letter from T. J. Dente (BWROG) to
D. G. Eisenhut (NRS), "Schedule for
BWR Owners Group Compliance with
NUREG-0737, Item II.K.3.18,
BWROG-8204, dated February 5, 1982.

Subject: Schedule for Detroit Edison's Compliance
with NUREG-0737 Item II.K.3.18,
"ADS-Logic Modification"

Reference 2 provides the technical basis for a need to
re-evaluate the ADS logic change proposed by the
Owners Group in response to NUREG-0737, Item II.K.3.18.

GE and the BWR Owners Group are in the process of
identifying the optimum logic design modifications
which would resolve the conflict between the operator
action specified in the Emergency Procedure Guidelines
and the requirement of NUREG-0737, Item II.K.3.18.

The Owners Group resolution of this issue is scheduled
for completion by September 30, 1982 (Reference 2).
Following NRC review and approval of final design
descriptions, individual utilities are to select one
of these options and proceed with the design descrip-
tion and implementation for its plant.

In view of these developments, Detroit Edison has put
the ADS logic change modification (FSAR H.II.K.3.18)
on hold.


A046
5
1/0

8205030176

R. L. Tedesco
April 26, 1982
EF2 - 56,943
Page 2

Detroit Edison is hereby requesting the NRC to grant
an extension on completion of modifications to the ADS
logic until the first refueling outage.

Sincerely,

A handwritten signature in cursive script, appearing to read "Harry Tauler".

cc: L. L. Kintner
B. Little