

## LICENSEE EVENT REPORT

CONTROL BLOCK (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y I P S 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5  
8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 80

CONT

0 1 REPORT SOURCE L 0 5 0 0 0 2 4 7 7 0 3 2 0 8 2 8 0 4 1 9 8 2 9  
8 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a routine inspection, valve 267A in the CVCs was found leaking. In order  
0 3 to isolate valve 267A to commence repair activities, the two boric acid transfer  
0 4 pumps (T.S. 3.2.C.2) and the boric acid storage system (T.S. 3.2.C.3) were  
0 5 isolated. A controlled shutdown was initiated. There were no other safety  
0 6 implications and the public's health and safety were unaffected.

0 7  
0 8  
8 9

0 9 SYSTEM CODE P C 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE D 15 VALVE SUBCODE G 16  
8 9 10 11 12 13 14 15 16 17 18 19 20  
17 LER/RO REPORT NUMBER 8 2 21 22 23 24 25 26 27 28 29 30 31 32  
EVENT YEAR 8 2 SEQUENTIAL REPORT NO. 0 1 4 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0  
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT B 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER X 9 9 9 9 26  
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 diaphragm failure on valve 267A was the cause of the leak. The valve was isolated,  
1 1 repaired, and returned to service, and plant shutdown was terminated and Unit load  
1 2 returned to the 100% licensed reactor power level.

1 3  
1 4  
8 9

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operator observation 32  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 6 ACTIVITY RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER Robert Fitzpatrick

PHONE: (914) 526-5349

NRC USE ONLY