

* On 3-29-82, following receipt of test results from Wyle Laboratory that indicated the snubber was inoperative, this report was reclassified as a 30 day letter. Further investigation into the cause of failure is in progress.



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 - 3 - 8 - 18
STA UNIT YEAR NO.

* SEE RECLASSIFICATION

PART 1 TITLE OF DEVIATION
Unit 3 Mechanical Snubber Failed Stroke Test
OCCURRED 2-15-82 0800
DATE TIMESYSTEM AFFECTED 1200 PLANT STATUS AT TIME OF EVENT
Rx H₂O Cleanup MODE Refuel PWR(MWT) 0 LOAD(MWE) 0 TESTING
YES NODESCRIPTION OF EVENT
During the stroke test of Pacific Scientific Mechanical Snubber #23 in
the Unit 3 drywell, operation of Snubber (3-1201-SR-3) found questionable.EQUIPMENT FAILURE 18716
10 CFR50.72 NRC RED PHONE YES NO
NOTIFICATION MADE YES NO
RESponsible SUPERVISOR Sang Rhee DATE 2/17/82PART 2 OPERATING ENGINEER'S COMMENTS
Consultations with a Pacific Scientific Factory Rep. disclosed that the snubber was operable
but not over its full range, i.e., it would not go to full compression. It stopped short by
about 1 inch. Discussion with EDS indicated that the snubber was not required to function
in the full compression range. The snubber is being sent to Wyle Labs for testing, dis-
assembly and repair.

<input type="checkbox"/> EVENT OF PUBLIC INTEREST	<input type="checkbox"/> 24-HOUR NRC NOTIFICATION REQ'D
<input type="checkbox"/> TECH. SPEC. VIOLATION	TELEPH Tom Tongue (courtesy) 7-23-82 1300
<input type="checkbox"/> NON REPORTABLE OCCURRENCE	* Notified of REGION III DATE TIME
<input type="checkbox"/> 14 DAY REPORTABLE/T.S.	change to 30 day ltr. Tom Tongue 3-29-82 1300
* <input checked="" type="checkbox"/> 30 DAY REPORTABLE/T.S. 6.6.B.2.b TELEGM/TELECOPY REGION III DATE TIME	
<input type="checkbox"/> ANNUAL/SPECL REPORT REQ'D	<input type="checkbox"/> CECO CORPORATE NOTIFICATION MADE
	IF ABOVE NOTIFICATION IS PER 10CFR21
	<input type="checkbox"/> 5-DAY WRITTEN REPORT REQ'D PER 10CFR21
	3-29-82 1522
A.I.R. #	TELEPH F. A. Palmer 2-24-82 1322
L.E.R. #82-16/03L-0	CECO CORPORATE OFFICER DATE TIME
Changed to 30 day ltr. 3-29-82 (over)	3-29-82

PRELIMINARY REPORT
COMPLETED AND REVIEWED Michael Wright 2-23-82
OPERATING ENGINEER DATE
INVESTIGATED REPORT & RESOLUTION
ACCEPTED BY STATION REVIEW J. Brunner 4/26/82 Michael Wright 4-27-82
RESOLUTION APPROVED AND
AUTHORIZED FOR DISTRIBUTION Douglas Scott 4/27/82
STATION SUPERINTENDENT DATE
88-5178 (FORM 15-52-1) 10-81