



ARKANSAS POWER & LIGHT COMPANY

POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

April 29, 1982

1CAN048209

Director of Nuclear Reactor Regulation
ATTN: Mr. J. F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
NUREG-0737 Item III.D.3.4
Control Room Habitability
(File: 1510.4)

Gentlemen:

Your letter dated February 12, 1982, (0CNA028210) requested a commitment and schedule to propose ANO-1 Technical Specifications that would require the control room chlorine detection and protection system be equally effective whether either ANO-1 or ANO-2 is at power. We hereby commit to propose ANO-1 Technical Specifications that will require chlorine detector operability similar to ANO-2. These proposed Technical Specifications will be submitted by June 16, 1982.

Very truly yours,

John R. Marshall
Manager, Licensing

JRM:nak
[initials]

A046
1/6

8205060246 820429
PDR ADOCK 05000313
P PDR