

ILLINOIS POWER COMPANY



U-0473

L30-82(04-30)-6

500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

April 30, 1982



Mr. James R. Miller, Chief
Standardization & Special Projects Branch
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Miller:

Clinton Power Station Unit 1
Docket No. 50-461

With reference to CPS SER Confirmatory Issue #8, "NSSS Pipe Break Analysis Using SRP Criteria (3.6.2)", General Electric Company has reanalyzed the piping in question using the 2.4Sm criteria as specified in the SRP. The analyses revealed that there were no more breaks using the 2.4Sm than there had been using 3.0Sm. Therefore, we consider this matter closed for licensing purposes.

Sincerely,

G. E. Wuller
Supervisor-Licensing
Nuclear Station Engineering

CCW/lc

cc: J. H. Williams, NRC Clinton Project Manager
H. H. Livermore, NRC Resident Inspector
D. Terao, Mechanical Engineering Branch
Illinois Dept. of Nuclear Safety

BOO/
1/0